



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

February 19, 2021

ADDENDUM # 1

Bid Number: 50-00133108

Receipt Date: February 25, 2021

Description of Bid: Two (2) year contract for concrete street maintenance for the Jefferson Parish Department of Public Works, Streets and all Jefferson Parish agencies and municipalities

CLARIFICATION:

Question 1:

For items such as 0010-0080, does the term "removal/disposal/replacement or new) mean that for this pay item, the unit price should include the removal, disposal, and the repouring of new concrete in its place?

- Example:

We need to know if that line item will be as such:

Removal - \$60/sqyd

Disposal - \$60/sqyd

Replace concrete - \$60/sqyd

Total would be \$180/yd

In this case, a project 100sqyd project would be \$18000 on that pay item Or, would it be \$60/sqyd for all three combined resulting in \$6000 for a 100sqyd project on that pay item?

Answer:

Correct. There will be no separate pay for removal or disposal when replacing concrete under these items. The unit cost for these items are to cover the expense of removal and disposal. And it goes without saying that there will be no different pay for pouring new panels where none existing before.

GENERAL GOVERNMENT BLDG. — 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. — 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET

If you bid \$180 per s.y. for any of those line items 0010-0080 and the area of concrete placed is 100 s.y., then the cost for that line item will be \$18,000 to remove the concrete, dispose of it, and pour new concrete in its place.

Question 2:

Who is the current contract holder

Answer:

Fleming Construction Company

Question 3:

Will JP issue the applicable pay items with the work orders or will vendors be responsible for classifying pay items?

Answer:

Jefferson Parish will have an inspector on site for each work order issued who will tell the contractor which items will be used for the work performed. Upon completion of any work order, the contractor and parish inspector will resolve quantities to be paid for work performed under the appropriate line items.

REVISION:

This addendum hereby revises and replaces the original bid form and specifications and is attached hereto. Bidders must submit this revised bid form with this submission. Failure to do so will result in bid rejection.

BID DUE DATE WILL REMAIN THE SAME FEBRUARY 25, 2021 AT 2:00 P.M.

Sincerely,

Daphne Nelson

Daphne Nelson
Buyer II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET

DATE: 2/19/2021

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 1

BID NO.: 50-00133108

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

BUYER: DNELSON@jeffparish.net

REVISED PER ADDENDUM 1

BIDS WILL BE RECEIVED ONLINE VIA WWW.JEFFPARISHBIDS.NET UNTIL 2:00 PM, 2/25/2021 AND PUBLICLY OPENED THEREAFTER IN THE WEST BANK PURCHASING DEPT, SUITE 4400, JEFFERSON PARISH GENERAL GOVERNMENT BUILDING, 200 DERBIGNY STREET, GRETNA, LA 70053 AND VIA TELECONFERENCE (DIAL-IN AT (504) 323-1800, MEETING ID: 181357) At no charge, bidders are to submit via Jefferson Parish's electronic procurement page by visiting www.jeffparishbids.net to register for this free site. Additional instructions are included in the text box highlighting electronic procurement.

LATE BIDS WILL NOT BE ACCEPTED

NOTE: ONLY BIDS WRITTEN IN INK OR TYPEWRITTEN, AND PROPERLY SIGNED BY A MEMBER OF THE FIRM OR AUTHORIZED REPRESENTATIVE, WILL BE ACCEPTED. PENCIL AND/OR PHOTOSTATIC FIGURES OR SIGNATURES SHALL RESULT IN BID REJECTION. HOWEVER, ELECTRONIC SIGNATURES AS DEFINED IN LSA - R.S. 9:2620(8) ARE ACCEPTABLE. SIGNATURE MUST BE A SECURED DIGITAL SIGNATURE.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

THE FOLLOWING INSTRUCTIONS APPLY TO ALL BIDS

All bids submitted are subject to these instructions and general conditions and any special conditions and specifications contained herein, all of which are made part of this bid proposal reference. By submitting a bid, vendor agrees to comply with all provisions of Louisiana Law as well be in compliance with the Jefferson Parish Code of Ordinances, Louisiana Code of Ethics, applicable Jefferson Parish ethical standards and Jefferson Parish Resolution No. 113646 and/or Resolution No. 113647.

Jefferson Parish adheres to the Louisiana Code of Governmental Ethics, contained in Louisiana Revised Statutes Annotated, R.S. 42:1101, et seq. Vendor/Proposer by this submission, warrants that there are no "conflicts of interest" related to this procurement that would violate applicable Louisiana Law. Violation of the Louisiana Code of Governmental Ethics may result in rescission of contract, permit or licenses, and the imposition of fines and/or penalties, without contractual liability to the public in accordance with applicable law.

All vendors submitting bids should register as a Jefferson Parish vendor if not already yet registered. Registration forms may be downloaded from <http://purchasing.jeffparish.net> and by clicking on Vendor Information. Current W-9 forms with respective Tax Identification numbers and vendor applications may be submitted at any time; however, if your company is not registered and/or a current W-9 form is not on file, vendor registration is mandatory. Vendors may experience a delay in payment if your company is not a registered vendor with Jefferson Parish.

All quotations shall be based on F.O.B. Agency warehouse or job site, anywhere within the Parish as designated by the Purchasing Department. This provision does not apply to public works projects

JEFFERSON PARISH requires all products to be new (current) and all work must be performed according to standard practices for the project. Unless otherwise specified, no aftermarket parts will be accepted. Unless otherwise specified, all workmanship and materials must have at least one (1) year guaranty, in writing, from the date of delivery and/or acceptance of the project. Any deviations or alterations from the specifications must be indicated and/or supporting documentation supplied with bid submission.

Bidders should submit all questions in writing via email to the buyer's email address as indicated above, no later than Five (5) working days prior to the bid opening. Bid numbers should be mentioned in all requests. If submitting online, vendors may send questions via the E-Procurement site no later than Five (5) working days prior to the bid opening.

If this bid requires a pre-bid conference (see Additional Requirements section), bidders are advised that such conference will be held to allow bidders the opportunity to identify any discrepancies in the bid specifications and seek further clarification regarding instructions. The Purchasing Department will issue a written response to bidders' questions in the form of an Addendum. Please note that all official communication will be expressed in the form of an addendum.

Visit our website at [HTTP://PURCHASING.JEFFPARISH.NET](http://PURCHASING.JEFFPARISH.NET)

DATE: 2/19/2021

BID NO.: 50-00133108

Page: 2

REVISED PER ADDENDUM 1

All formal Addenda require written acknowledgement on the bid form by the bidder. Failure to acknowledge an Addendum on the bid form shall cause the bid to be rejected. JEFFERSON PARISH reserves the right to award bid to next lowest responsive and responsible bidder in this event.

JEFFERSON PARISH will accept one price for each item unless otherwise indicated. Two or more prices for one item will result in bid rejection. Bidders are required to complete, sign and return the bid form and/or complete and return the associated line item pricing forms as indicated. Vendors must not alter the bid forms. Doing so will cause the bid to be rejected.

A corporate resolution or written evidence of the individual signing the bid having such authority must be submitted with the bid. Failure to comply will cause bid to be rejected. For corporate entities, such written evidence may be a printout of the Louisiana Secretary of State's website listing the signatory as an officer. Such printout shall be included with the bid submission. Bids submitted by Owners or Sole Proprietorships must include certification that he or she owns the entity for which the bid is signed. This documentation must be submitted with the bid. Failure to do so will result in bid rejection.

NOTE: A sample corporate resolution can be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document. A sample certification of sole proprietorship can also be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

A. AWARD OF CONTRACT: JEFFERSON PARISH reserves the right to award contracts or place orders on a lump sum or individual item basis, or such combination, as shall in its judgment be in the best interest of JEFFERSON PARISH. Every contract or order shall be awarded to the LOWEST RESPONSIVE AND RESPONSIBLE BIDDER, taking into consideration the CONFORMITY WITH THE SPECIFICATIONS and the DELIVERY AND/OR COMPLETION DATE. SPLIT AWARDS MADE TO SEVERAL VENDORS WILL ONLY BE GRANTED TO THOSE DEEMED RESPONSIVE AND RESPONSIBLE.

All bid prices shall remain valid for 45 days. Jefferson Parish and the lowest responsive and responsible bidder(s) by mutual written consent may mutually agree to extend the deadline for award by one (1) or more extensions of thirty (30) calendar days.

PROTESTS: Only those vendors that submit bids in response to this solicitation may protest any element of the procurement, in writing to the Director of the Purchasing Department. Written protest must be received within 48 hours of the release of the bid tabulation by the Purchasing Department. After consultation, the Parish Attorney's Office will then respond to protests in writing. (For more information, please see Chapter 2, Article VII, Division 2, Sec. 2-914.1 of the Jefferson Parish Code of Ordinances.)

PREFERENCE: Unless federal funding is directly spent by Jefferson Parish for this purchase, preference is hereby given to materials, supplies, and provisions produced, manufactured or grown in Louisiana, quality being equal to articles offered by competitors outside the state. "LSA - R.S. 38:2251-2261"

B. USE OF BRAND NAMES AND STOCK NUMBERS: Where brand names and stock numbers are specified, it is for the purpose of establishing certain minimum standards of quality. Bids may be submitted for products of equal quality, provided brand names and stock numbers are specified. Complete product data may be required prior to award.

C. CANCELLATION OF CONTRACT: JEFFERSON PARISH reserves the right to cancel all or any part if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel any contract at anytime and for any reason by issuing a THIRTY (30) day written notice to the contractor.

For good cause and as consideration for executing a contract with Jefferson Parish, vendor conveys, sells, assigns and transfers to Jefferson Parish or its assigns all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of Louisiana, relating to the particular good or services purchased or acquired by Jefferson Parish.

D. PRICES: Jefferson Parish is exempt from paying sales tax under LSA-R.S. 47:301 (8)(c). All prices for purchases by Jefferson Parish of supplies and materials shall be quoted in the unit of measure specified and unless otherwise specified, shall be exclusive of state and local taxes. For purchases of labor and materials, the Contractor shall not pay any state or local sales or use taxes on materials and equipment which are affixed and made part of the immovable property of the project or which permanently incorporated in the project (hereinafter referred to as "applicable materials and equipment"). All purchases of applicable materials or equipment shall be made by the contractor on behalf of and as the agent of Jefferson Parish (Owner), a political subdivision of the State of Louisiana. No state and local sales and use taxes are owned on applicable materials and equipment under the provisions of Act 1029 of the 1991 Regular Session - Louisiana Revised Statute 47:301(8)(c). Owner will furnish contractor a certificate form which certifies that Owner is not required to pay such state or local sales and use taxes, and contractor shall furnish a copy of such certificate to all vendors or suppliers of the applicable materials and equipment. The price quoted for work shall be stated in figures. In the event there is a difference in unit prices and totals, the unit price shall prevail.

Quantities listed are for bidding purposes only. Actual requirements may be more or less than quantities listed.

Bidders are not to exclude from participation in, deny the benefits of, or subject to discrimination under any program or activity, any person in the United States on the grounds of race, color, national origin, or sex; nor discriminate on the basis of age under the Age Discrimination Act of 1975, or with respect to an otherwise qualified handicapped individual as provided in Section 504 of the Rehabilitation Act of 1973, or on the basis of religion, except that any exemption from such prohibition against discrimination on the basis of religion as provided in the Civil Rights Act of 1964, or Title VI and VII of the Act of April 11, 1968, shall also apply. This assurance includes compliance with the administrative requirements of the Revenue Sharing final handicapped discrimination provisions contained in Section 51.55 (c), (d), (e), and (k)(5) of the Regulations. New construction or renovation projects must comply with Section 504 of the 1973 Rehabilitation Act, as amended, in accordance with the American National Standard Institute's specifications (ANSI A17.1-1961).

DATE: 2/19/2021

BID NO.: 50-00133108

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

Page: 3

REVISED PER ADDENDUM 1

Jefferson Parish and its partners as the recipients of federal funds are fully committed to awarding a contract(s) to firm(s) that will provide high quality services and that are dedicated to diversity and to containing costs. Thus, Jefferson Parish strongly encourages the involvement of minority and/or woman-owned business enterprises (DBE's, including MBE's, WBE's and SBE's) to stimulate participation in procurement and assistance programs.

The purpose and intention of this invitation to bid is to afford all suppliers an equal opportunity to bid on all construction, maintenance, repair, operating supplies and/or equipment listed in this bid proposal. JEFFERSON PARISH WILL ACCEPT ONE BID ONLY FROM EACH VENDOR. Items bid must meet specifications.

Advertised bids will be tabulated and a copy of the tabulation will be forwarded to each responding bidder.

IN ACCORDANCE WITH STATE REGULATIONS JEFFERSON PARISH OFFERS ELECTRONIC PROCUREMENT TO ALL VENDORS

This electronic procurement system allows vendors the convenience of reviewing and submitting bids online. This is a secure site and authorized personnel have limited read access only. Bidders are encouraged to submit electronically using this free service; while the website accepts various file types, one single PDF file containing all appropriate and required bid documents is preferred. Bidders submitting uploaded images of bid responses are solely responsible for clarity. If uploaded images/documents are not legible, then bidder's submission will be rejected. Please note all requirements contained in this bid package for electronic bid submission.

Please visit our E-Procurement Page at www.jeffparishbids.net to register and view Jefferson Parish solicitations. For more information, please visit the Purchasing Department page at <http://purchasing.jeffparish.net>.

The general specifications for construction projects and the purchase of materials, services and/or supplies are those adopted by the JEFFERSON PARISH Council by Resolution No. 113646 or 113647 as amended. The general conditions adopted by this resolution shall be considered as much a part of this document as if they were written wholly herein. A copy may be obtained from the Office of the Parish Clerk, Suite 6700, Jefferson Parish General Government Building, 200 Derbigny Street, Gretna, LA 70053. You may also obtain a copy by visiting the Purchasing Department webpage at <http://purchasing.jeffparish.net> and clicking on Online Forms.

ADDITIONAL REQUIREMENTS FOR THIS BID

PLEASE MATCH THE NUMBERS PRINTED IN THIS BOX WITH THE CORRESPONDING INSTRUCTIONS BELOW.

2,3,4,6,7,10,11,12,13,14,17

1. All bidders must attend the MANDATORY pre-bid conference and will be required to sign in and out as evidence of attendance. In accordance with LSA R.S. 38:2212(l), all prospective bidders shall be present at the beginning of the MANDATORY pre-bid conference and shall remain in attendance for the duration of the conference. Any prospective bidder who fails to attend the conference or remain for the duration shall be prohibited from submitting a bid for the project.
2. Attendance to this pre-bid conference is optional. However, failure to attend the pre-bid conference shall not relieve the bidder of responsibility for information discussed at the conference. Furthermore, failure to attend the pre-bid conference and inspection does not relieve the successful bidder from the necessity of furnishing materials or performing any work that may be required to complete the work in accordance with the specification with no additional cost to the owner.
3. Contractor must hold current applicable JEFFERSON PARISH licenses with the Department of Inspection and Code Enforcement. Contractor shall obtain any and all permits required by the JEFFERSON PARISH Department of Inspection and Code Enforcement. The contractor shall be responsible for the payment of these permits. All permits must be obtained prior to the start of the project. Contractor must also hold any and all applicable Federal and State licenses. Contractor shall be responsible for the payment of these permits and shall obtain them prior to the start of the project.
4. A LA State Contractor's License will be required in accordance with LSA R.S. 37-2150 et. seq. and such license number will be shown on the outside of the bid envelope. Failure to comply will cause the bid to be rejected. Additionally if submitting the bid electronically, then the license number must be entered in the appropriate field in the Electronic Procurement system. Failure to comply will cause the bid to be rejected.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

4. A LA State Contractor's License will be required in accordance with LSA R.S. 37-2150 et. seq. and such license number will be shown on the outside of the bid electronic envelope. Failure to comply will cause the bid to be rejected. When submitting the bid electronically, the license number must be entered in the appropriate field in the electronic procurement system. Failure to comply will cause the bid to be rejected.
5. It is the bidder's responsibility to visit the job site and evaluate the job before submitting a bid.
6. Job site must be clean and free of all litter and debris daily and upon completion of the contract. Passageways must be kept clean and free of material, equipment, and debris at all times. Flammable material must be removed from the job site daily because storage will not be permitted on the premises. Precaution must be exercised at all times to safeguard the welfare of JEFFERSON PARISH and the general public.
7. PUBLIC WORKS BIDS: All awards for public works in excess of \$5,000.00 will be reduced to a formal contract which shall be recorded at the contractor's expense with the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. A price list of recordation costs may be obtained from the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. All awards in excess of \$25,000.00 will require both a performance and a payment bond. Unless otherwise stated in the bid specifications, the performance bond requirements shall be 100% of the contract price. Unless otherwise stated in the bid specifications, the payment bond requirements shall be 100% of the contract price. Both bonds shall be supplied at the signing of the contract.
8. NON-PUBLIC WORKS BIDS: A performance bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The performance bond shall be supplied at the signing of the contract.
9. NON-PUBLIC WORKS BIDS: A payment bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The payment bond shall be supplied at the signing of the contract.
10. All bidders must comply with the requirements stated in the attached "Standard Insurance Requirements" sheet attached to this bid solicitation. Failure to comply with this instruction will result in bid rejection.
11. A bid bond will be required with bid submission in the amount of 5% of the total bid, unless otherwise stated in the bid specifications. All sureties must be in original format (no copies) When submitting a bid online, vendors must submit an electronic bid bond through the respective online clearinghouse bond management system(s) as indicated in the electronic bid solicitation on Central Auction House. No scanned paper copies of any bid bond will be accepted as part of the electronic bid submission.
12. This is a requirements contract to be provided on an as needed basis. JEFFERSON PARISH makes no representations on warranties with regard to minimum guaranteed quantities unless otherwise stated in the bid specifications.
13. Freight charges should be included in total cost when quoting. If not quoted FOB DELIVERED, freight must be quoted as a separate item. Bid may be rejected if not quoted FOB DELIVERED or if freight charges are not indicated on bid form.
14. PUBLIC WORKS BIDS - Completed, Signed and Properly Notarized Affidavits Required; This applies to all solicitations for construction, alteration or demolition of public buildings or projects, in conformity with the provisions contained in LSA-RS 38:2212.9, LSA-RS 38:2212.10, LSA-RS 38:2224, and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Conviction Affidavit, Non-Collusion Affidavit, Campaign Contribution Affidavit, Debt Disclosures Affidavit and E-Verify Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.

DATE: 2/19/2021

BID NO.: 50-00133108

Page: 5
REVISED PER ADDENDUM 1

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

15. NON PUBLIC WORK BIDS - Completed, Signed and Properly Notarized Affidavits Required in conformity with the provisions contained in LSA – RS 38:2224 and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Collusion Affidavit, Debt Disclosures Affidavit and Campaign Contribution Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled NON PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.

16. The ensuing contract for this bid solicitation may be eligible for FEMA reimbursement and/or Federal funding/reimbursement. As such, the referenced appendix will be applicable accordingly and shall be considered a part of the bid documents. All applicable certifications must be duly completed, signed and submitted with bid submission. Failure to submit applicable certifications with bid submission will result in bid rejection.

17. For this project, the Contractor shall not pay any state or local sales or use taxes on materials and equipment which are affixed and made part of the immovable property of the project or which is permanently incorporated in the project (hereinafter referred to as "applicable materials and equipment."). All purchases of applicable materials or equipment shall be made by the contractor on behalf of and as the agent of Jefferson Parish (Owner), a political subdivision of the State of Louisiana. No state and local sales and use taxes are owed on applicable materials and equipment under the provisions of Act 1029 of the 1991 Regular Session - Louisiana Revised Statute 47:301(8)(c). Owner will furnish to contractor a certificate form which certifies that Owner is not required to pay such state or local sales and use taxes, and contractor shall furnish a copy of such certificate to all vendors or suppliers of the applicable materials and equipment, and report to Owner the amount of taxes not incurred.

It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission: and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the Inspector General in any investigation, audit, inspection, performance review, or hearing pursuant to JPCO 2-155.10(19). By signing this document, every corporation, partnership, or person contracting with PARISH, whether by cooperative endeavor, intergovernmental agreement, bid, proposal, application or solicitation for a parish contract, and every application for certification of eligibility for a parish contract or program, attests that it understands and will abide by all provisions of JPCO 2-155.10.

See Page 1 for Conflicts of Interest Statement

CONCRETE (STREET) MAINTENANCE

Two (2) year contract for Concrete (Street) Maintenance for the Jefferson Parish Department of Public Works – Streets and all Jefferson Parish agencies and municipalities (excluding Grand Isle).

BONDS:

Surety Bond: A bid bond in the amount of 5% of the bidders total and is required with bid submission.

Performance Bond: A performance bond in the amount of 50% of the contract total is required at the signing of the formal Contract.

Payment Bond: A payment bond in the amount of 50% of the contract total is required at the signing of the formal contract.

LOUISIANA STATE CONTRACTOR'S LICENSE: Vendor must have a Louisiana State Contractor's License in the Category of Highway, Street, and Bridge Construction.

GENERAL SPECIFICATIONS:

All work shall be performed in accordance with Jefferson Parish Standard Details for Roadways, Sidewalks and Curbs, as well as applicable utilities. Copies are available at the Department of Engineering, Suite 802, Yenni Building.

The terms and conditions of Resolution 113646, as amended, will be considered a part of the bid whether attached or not. A copy may be obtained from the Office of the Parish Clerk, 6th Floor, General Government Building, 200 Derbigny Street, Gretna, LA 70053.

Service Engineer

A person with license as a professional engineer in accordance with State of Louisiana Law, who is employed by the contractor to provide technical direction of the maintenance service.
Initials (Abbreviations)

AASHTO – American Association of State Highway and Transportation Officials

ACI – American Concrete Institute

ANS – American National Standards

ASA – American Standards Association

ASTM – American Society for Testing Materials

ATSSA – American Traffic Safety Services Association

AWWA – American Water Works Association

JPDPW – Jefferson Parish Department of Public Works

LADOTD – Louisiana Department of Transportation and Development

This is a "Concrete (Street) Maintenance Contract". It is intended to supplement work performed by regular maintenance forces of the Department of Public Works – Streets. Types of work under this contract include, but are not limited to concrete maintenance projects such as: concrete slab removal and replacement, concrete curb repairs, roadway revisions such as the addition of concrete turning lanes and median crossings, sidewalk/handicap ramp and drive apron replacement and new installations (typically when in conjunction with a work order that includes panel replacement, but may be without panel replacement), additions or revisions to subsurface drainage systems and structures.

The contract will be for a period of two (2) years. Contract prices are firm during the entire two (2) year contract period.

The quantities in the proposal form are approximate for the comparison of bids only. The parish reserves the right to purchase only such items and in such quantities as needed for the duration of this contract after acceptance of the lowest responsible bid by the parish governing authority.

The definition of "JOB" shall be the work described on any one issued work order. Each "JOB" shall be estimated as to time required to complete the amount of work proposed. Many "JOB" sizes will be relatively small: that is, the paving of several street panels having a normal width of 13 feet and each being from 15 to 20 feet in length. However, some "JOBS" may require the paving of several adjoining panels resulting in hundreds of square yards of paving. Most of the work areas are residential streets. Occasionally contracts may involve replacing slabs on major streets (minimum thicknesses of 9"/10" for slabs are required on these streets). Contractor may also be required to replace slabs as soon as possible in the event of blowouts.

Contractor shall supply a minimum of (3) complete crews for the duration of this contract. A complete crew shall be comprised of all qualified persons and equipment required to remove / dispose of existing concrete, form-up, and pour / finish new concrete pavement (i.e. 1 complete crew = breakout crew + form-up crew + pour / finishing crew). Having one breakout crew that proceeds from one work order location to the next work order location in advance of the subsequent form-up crews will not be allowed.

Each work order will be issued in writing with appropriate drawings if required, or other attachments and will designate a job number (WO#XX-XXX). All correspondence, billing, etc., pertaining to the work should reference the job number. Payment will be made upon receipt of detailed and itemized invoices and verification by parish inspectors regarding quantity and quality of work performed. Partial payment will be made only when completion is unduly delayed through no fault of the contractor in which case requests for partial payment may be submitted monthly.

All of the work within the limits of each job shall be shown to the contractor by a representative of the Department of Public Works prior to commencing work. If required, appropriate sketches and/or drawings may be furnished to the contractor with each work order. Work sites may be scattered for an individual work order; however, every effort will be made to consolidate the work to minimize scattered work sites. The contractor shall begin the work within 10 calendar days after issuance date of a work order. All street layouts/surveying for each work order shall be incidental to the bid items with no additional payment.

Each work order must be completed in a timely manner based on the area of concrete panels being replaced. If the work order is not completed in the specified time from the first day on site, then liquidated damages will be assessed. See the table below for time allowed:

Job Size (s.y. of PCCP)	Allotted Construction Time (calendar days)*
100 or less	21
101-300	50
Greater than 300	100

* Only the Director (of Streets Dept.) can approve the work to go beyond the days stipulated in the table above depending on the size / scope of the project.

If any work order does not begin in the allotted commencement time period (10 calendar days from issuance) or work remains incomplete past the allotted construction time (based on the table above), then the contractor will be assessed a liquidated damage cost of **\$250 per day** past the required start date and/or required completion date. The liquidated damage cost will be deducted from the final individual work order invoice.

Time extension will be granted for excusable days that are not the contractor's fault (like water or sewer leaks) and for inclement weather days. Excusable days must be documented in writing (email) by the contractor and are subject to approval by the Director (of Streets Dept.). Inclement weather days shall be defined as any day on which construction operations were unable to proceed for at least five (5) continuous hours of the day or 65% of the regular working hours, whichever is greater. Should the contractor prepare to begin work on any given day in which inclement weather or the site conditions resulting from previous inclement weather prevent work from starting at the usual time (and the crew is dismissed as a result thereof), then the day will be declared an inclement weather day, regardless if conditions improve, resulting in the rest of the day becoming suitable for work. Inclement weather days must be documented by the contractor and are subject to the approval by the Director (of Streets).

If contractor leaves the job incomplete for over a 30 day period, the parish has the right to use other Parish contracts as a means to complete outstanding work and the ability to bill the current contractor with those charges incurred. However, if the contractor has a valid reason to hold off on a job, he has to obtain written permission from the Director of Streets for the stipulated delay.

Also, the owner has the right to put a hold on a job at the beginning or when job is in progress without designating a reason. If the job is discontinued, the contractor will be compensated only for the items of work actually done and not for any down time.

Contractor shall not work during the holidays observed by Jefferson Parish unless otherwise authorized in writing by the director.

Contractor shall not schedule any contract work on major roads and thoroughfares between Thanksgiving and New Year holidays, or during Mardi Gras season.

If any sworn statements of claims are filed during the term of this contract, the parish shall withhold the next accruing payment and shall have the authority to satisfy the claim and deduct the amount from payments due.

If any liens arising out of this contract should be discovered to exist after all payments are made, the contractor shall refund the parish all monies that the latter may be compelled to pay in discharging such liens, including litigation costs and attorney's fees.

Adequate safety precautions will be taken for all work performed under this contract. Necessary barricades, signs, lights and warning devices including arrowboard if required will be installed and maintained by the contractor in accordance with Parish Traffic Engineering and Safety Standards.

All traffic control devices shall be defined as all signs, signals, markings and other devices used to regulate, warn, or guide traffic, placed on, over, or adjacent to a street, highway, pedestrian facility, or bikeway under the jurisdiction of Jefferson Parish.

All traffic control devices utilized under the terms of this contract shall be in accordance with the "Manual of Uniform Traffic Control Devices" (Latest Edition) as published by the American Traffic Safety Services Association (ATSSA).

The contractor shall be responsible for, at their own expense, providing safe and expeditious movement of traffic through construction zones, i.e., the immediate area of actual construction and all abutting areas used by the contractor and which interferes with the driving or walking public. Contractor responsibility includes, but is not limited to such items as proper construction warning signs, signals, lighting devices, (including electrical/electronic flashing arrow board), markings, barricades, channelization, hand signaling devices, (flagging operations), construction warning signs, detour routing, and any/all additional signage required for proper traffic control shall be provided by the contractor at no additional expense to Jefferson Parish. The Principal and Prescribed Standards are set forth in Part VI of the Manual on Uniform Traffic Devices, Latest Edition. Part VI shall be strictly followed.

All of the signing and traffic control devices shall be approved by the Office of Traffic Engineering, Jefferson Parish Department of Public Works prior to starting the job. All expenses incurred by the contractor to maintain traffic flow is incidental to the job, there shall be no added or additional payment.

Contractor shall inspect all overhead, surface and sub-surface utility lines prior to start of the project. During the performance of all work outlined in these specifications, the contractor will exercise due caution regarding underground utilities and will cooperate with representatives of the utility companies and/or parish departments to avoid damage to their installations. However, contractor is ultimately responsible for all damages by his actions.

Contractor must locate, protect, support and maintain all subsurface, surface and aerial utilities. In the event of any damage to existing utilities, contractor shall restore service, as soon as possible at contractor's expense. Contractor shall have the sole responsibility of resolving any lawsuit and liabilities arising from defective workmanship, improper maintenance of utilities and/or work site.

If there are any conflicting utilities that need relocation or adjustments, the contractor will allow reasonable time to accomplish this task. There is no added compensation for delays and cost caused by the conflict.

Contractor should consult with the Department of Public Works Traffic Engineering Division immediately upon any vehicular or pedestrian safety or efficiency problem incurred as a result of construction of a project.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0010 THRU 0190 and ITEMS 0250 THRU 300:**

- **REMOVAL / DISPOSAL (when applicable)**

Bid prices should include all costs for labor, equipment and material necessary to remove and dispose of existing pavement for the thickness as shown. Curbing removed with the slab will be at no additional cost. Should the parish desire, the contractor shall dump broken pavement at a disposal site designated by the parish at no added cost, provided that the disposal (dumping) site is within a 21-mile radius of the work site and may involve crossing the Mississippi River. Additionally, should the parish desire, the contractor will load broken pavement onto parish trucks at the work site at no added cost, provided that the parish trucks are present at the work site for loading as the pavement is being removed and do not unduly delay the contractor's work.

Care must be exercised so that jointing materials and devices adjacent to the concrete to be removed shall not be damaged. Any pavement damaged by the contractor as a result of negligence, either willful or accidental, will be replaced at the contractor's expense.

- **REPLACEMENT / NEW PAVEMENT**

4000 PSI – 24 Hours – High early strength with superplasticizer and other additives, if applicable.

4000 PSI – 72 Hours – High early strength with superplasticizer and other additives, if applicable.

This item covers the furnishing of all materials and installation of PCC pavements for thickness as shown. Concrete shall be Class A, 4000 PSI 24/72 hours high early strength.

Bid prices shall also include adequate curing of the concrete placed and the proper sealing of contraction and expansion joints.

Bid prices shall include all costs for labor, equipment and materials described under this item of the bid proposal. All required jointing materials (including joint sealant) shall be included in price bid under each item. Method of jointing shall be the same as the existing joints in the area of work.

Damaged, missing, and/or new dowel bars (longitudinal/transverse) and starlugs shall be replaced at no additional cost to the parish – 1" x 18" smooth dowel bars for 7" thick pavement (1-1/4" x 18" smooth dowel bars for 9" or thicker pavement) shall be used. The bars shall be placed in the existing pavement by drilling holes to a depth of 9" and filling with an approved epoxy grout before insertion of the dowel bars. Contractor is responsible for any deformed bars for longitudinal joints. If toeing under the slab is approved as an option by the parish representative in lieu of doweling, there is no additional compensation for concrete used for toeing. All costs incurred for this task will be the contractor's responsibility. Bid prices shall also include adequate curing of the newly placed concrete and the proper sealing of contraction and expansion joints of the newly placed concrete.

Bid prices shall also include cost of providing engineering/surveying for alignment, grade, profile, survey stakes, topography when necessary and as required to improve the roadway alignment, curb and gutter layout, drain line installation, etc. Compensation for this shall be incidental to corresponding bid items in the maintenance contract. There is no other compensation. This includes new road, extension of existing road and turning lanes, parking lots, bike and walking trails, etc. All layouts shall be the responsibility of the contractor.

Contractor to provide a procedure (with applicable drawings) for concrete vibration (consolidation) that will be used for all street panels that are poured. It is to be detailed with spacings and durations for the vibrating process.

***To be clear: Bid prices for these items include removal, disposal (when applicable) of existing pavement (with or without curbing) and replacement/new pavement including curb (when applicable).

***Average thickness of pavement being removed may vary a few inches (± 2 inches) from the actual new pavement thickness being replaced. Average thickness will be based on 4 spot measurements.

Mixes shall conform to Louisiana Department of Transportation and Development Standard Specifications for Roads and Bridges, Latest Edition.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0192 AND 0194:**

These items will be used when the Parish has a desire to remove concrete pavement, without any intent to restore it.

For instance, remove an existing u-turn/turn lane and fill void with dirt/soil.

For clarity, the contractor will NOT be paid for removal under this item when replacing a damaged street panel.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0040 AND 0080:**

HANDICAPPED RAMPS:

Six (6) inch and eight (8) inch 4000 PSI/72 hour high early strength concrete for handicapped ramps, with welded wire mesh.

Where necessary or as directed by the engineer, existing sidewalk and curbing at intersections and medians shall be broken out/or saw cut, removed and replaced with a new Portland cement concrete curb ramp for the handicapped. Curb ramps shall conform to ADAAG (Americans with Disabilities Acts Accessibility) guidelines 4.7.

The detectable warning provided shall be paid at bid unit price (**ITEM 0830**). Bid unit price should include cost for labor, equipment and materials necessary to install masonry units as per Jefferson Parish Standard Plans. Detectable warning shall contrast visually with adjoining surface (reddish like "terra cotta"). 24" x 48" cast-in-place detectable warning system must have

raised truncated domes per ADAA specifications. Contractor must use one-piece truncated dome mats/pads made of a homogenous glass and carbon reinforced composite which is colorfast and UV stable. Panel color shall be uniform throughout. Backside of panel should have ribs that embed within the curing concrete.

Batture sand for dress, breaking out and removal of existing sidewalk will be paid for in other items.

Any other materials or labor needed to accomplish curb ramps for the handicapped must be incidental to the above items.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0200 THRU 0240:**

Additional charge for replacing special/decorative pavement surfaces with in-kind material.

Contractor must get approval from Jefferson Parish Department of Streets (Inspectors) prior to selecting/finalizing replacement material.

Payment will be per square yard of pavement surface that is reinstalled.

All labor and material incidental to the installation of the pavement surface shall be included in this price.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0242 AND 0244:**

PERVIOUS CONCRETE PAVEMENT:

This work consists of furnishing all material, equipment and labor required for the construction of patterned, colored, pervious ornamental concrete pavement (sidewalks, driveway aprons, etc.) and pervious concrete parking areas in accordance with the lines and grades established in the field by the Parish Inspector / Engineer. Work shall conform to all requirements of ACI 522.1-13, 'Specification for Pervious Concrete Pavement,' published by the American Concrete Institute, except as modified herein. When applicable, work shall be performed in accordance with the provisions of Section 706 of the Louisiana Standard of the Specifications for Roads and Bridges, 2006 Edition (Blue Book), and latest revisions, except as otherwise noted in these specifications.

MATERIALS:

The pervious concrete used for pavements shall comply with the mixture proportions specified herein.

Mixture Proportioning:

- The total cement content shall be a minimum of 630 lbs. /CY.
- Fly Ash shall not exceed 20% and Slag shall not exceed a 50% maximum.

- The maximum water-cement ratio for shall be 0.35.

The bulk volume of aggregate per cubic yard shall be equal to 27 cubic feet when calculated from dry rodded density (unit weight) determined in accordance with ASTM C29. Fine aggregate, if used, should not exceed three (3) cubic feet and shall be included in the total aggregate volume.

Admixtures shall be used in accordance with manufacturer's recommendations.

The quantity of water used in the pervious concrete mixture shall facilitate placing, compaction, and finishing to the desired surface characteristics. The appropriate water content will give the mix a wet metallic sheen without causing the cement to flow from the aggregate and be sufficient for adequate hydration. If the water content is too low, the mix may be inconsistent and produce poor bond strength. A high water content may cause the cement to migrate toward the bottom and fill the voids as well as create a poor surface bond.

Testing shall be in accordance with ACI 522.1-13 Section 1.5.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0280 THRU 0300:**

4000 PSI high early strength (24 or 72 hours), (No. 4 deformed reinforcing bars are to be included in price of this item. If a detail does not exist for a specific case, then contractor shall place bars on top and bottom level of box-out, around the entire perimeter and then across both directions @ 6 inches on center).

Bid prices to include material, labor and equipment necessary to remove and replace a box-out on an existing pavement, or to install on new pavement.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEM 0350**

Specifications shall be in accordance with Louisiana Standard Specifications for Roads and Bridges under "STONE". In addition, material shall be calcitic or dolimitic with calcium carbonate not less than 85% and the silica content (impurities) not to exceed 5%.

Limestone used on asphalt pavement shoulders shall be comparable to Mexican limestone in color and gradation.

Shoulder Aggregate:

This material shall conform to the following gradation:

Limestone

U.S. Sieve	Percent Passing
1.5"	100
0.75"	50-100

No. 4	35-65
No. 40	10-32
No. 200	3-15

Aggregate shall conform to LADOTD Standard Specifications for Roads and Bridges, Subsection 1003.01, Latest Edition.

The fraction of stone passing the No. 40 sieve shall be non-plastic.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0310 THRU 0360:**

These items cover work and material generally associated with base, shoulder, drainage and dress-up work. Excavation will be paid by cubic yard truck measure loaded at the job sites or by computing theoretical volume at the approval of the parish representative. Fill materials will be paid by cubic yard truck measure delivered to the work site. Bid prices shall include costs for compaction and grading of materials when used for base construction. Should the parish desire, the contractor will dump excavated materials at a disposal site designated by the parish at no added cost, provided that the disposal (dumping) site is within a 21-mile radius of the work site and may involve crossing the Mississippi River. Additionally, should the parish desire, the contractor will load excavated material onto parish trucks at the work site at no added cost provided that the parish trucks are present at the work site at the time of excavation and do not unduly delay the contractor's work. However, ultimate responsibility for disposal of all the excavated material rests with the contractor. Haul and/or loading tickets will be issued for each truck load of material delivered and placed on the job and/or truck load of excavated material haul from the job site.

All the original haul tickets must be furnished by the contractor for payment.

The contractor will exercise due caution regarding underground utilities during excavation operations and will notify and coordinate with representatives of utility companies and parish departments to avoid damage to their installations. However, contractor is ultimately responsible for all damages caused by his actions. Also, if any conflicting utility needs "relocation or adjusting", the contractor will allow reasonable time to accomplish the task. There will be no additional compensation for the time delay caused by the conflicts.

No trucks with greater load capacity than 18 cubic yards shall be allowed on residential streets for excavation, concrete/asphalt removal or fill material delivery without authorization from the engineer. Should the contractor fail to meet this condition, all damage resulting will be repaired at the contractor's expense.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0370 THRU 0570:**

Bid prices should include all cost of labor, materials (pipe, excavation, bedding, boards, fill, etc.) and equipment necessary to install new drain pipe and/or remove and replace existing drain pipe as described under this item of the proposal. All workmanship and material shall be in accordance with Jefferson Parish Department of Engineering Standard Plans. (Boards shall be

used during the installation of concrete pipe.) Each joint will be wrapped with filter cloth 36" wide, and over lapped, a minimum of 36".

SDR 35 P.V.C. pipe shall not be used for any new crossings below the roadway.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0580 THRU 0800:**

Specific depths for drain structures will vary with each project. However, it is anticipated that most subsurface drainage systems installed under this contract will be generally shallow. For bidding purposes, drain structure depths should be assumed in the 3 to 5 ft. range as an average.

Reinforcing for base slab shall be No. 5 bars at 6" O.C. minimum each way (3" above bedding material), and shall be included in the price of the structure.

Frames, grates and covers for manholes, catch basins and drop inlet should be the heavy duty type. The only acceptable frames, grates and covers are those which are domestically manufactured. All castings shall be clearly stamped or engraved with the manufacturer's name and part number on the casting.

Foundation for all drainage structures should follow Jefferson Parish Standard Details.

Oversized junction boxes (special) shall be compensated at bid unit prices. The cost shall include all necessary material including reinforcing steel and labor. The height and base area are used as guidance for bidding purposes only. Minimum reinforcing for the base slab shall be 2 layers of No. 6 bars on 6" O.C. each way, 3" cover for bottom steel and 2" cover for top steel. Concrete for the box shall be Class A. The design for the drainage structures at each location shall be submitted by the contractor for approval by the department director.

Occasionally this contractor may be required to install drainage inlets (and drain pipes) to remove ponding water and bird baths. All drainage box (and drain pipe) installations will follow Jefferson Parish Department of Public Works procedures. Bid prices for the drainage structure (box/inlet) shall include the bricks/mortar to construct the box, bedding material, foundation, (and reinforcing bars), excavation, backfill materials, etc. as required. (See spec for Items 0370 thru 0570 regarding bid price for pipe.)

Typical details for construction of drain structures are available from the Department of Public Works upon request.

**THE BELOW SPECIFICATIONS APPLY TO
ITEM 0810:**

Machine saw cuts in concrete/asphalt shall be paid for by linear foot of cut and the depths shall be pre-approved by parish representatives and measured in the field

**THE BELOW SPECIFICATIONS APPLY TO
ITEM 0830:**

Detectable Warning Pad (24" x 48") with Raised Truncated Domes (Per ADA Guidelines), Visually Contrasting with Adjoining Surfaces (Reddish Like "Terra Cotta" In-Place for Curb Ramps and Loading Zones)

Bid unit price should include the cost for labor, equipment and materials necessary to install detectable warning pads with raised truncated domes as per Jefferson Parish Standard Plans. Detectable warning shall contrast visually with adjoining surface (reddish like "TERRA COTTA"). Detectable warning pad should be set into concrete as it is curing/wet.

Descriptions:

This cast in place detectable warning system is to be used for the construction of new handicap ramps. The cast in place detectable warning systems must have a minimum 0.20 inch nominal thickness and feature embedment ribs through entire length of the panel (maximum rib spacing of 3 inch on center). This product must be in accordance with ADA regulations for detectable warning on curb ramps.

Material:

This product is made of a homogenous glass and carbon reinforced composite which is colorfast and UV stable. Truncated domes are fiberglass reinforced for enhanced durability. The panel color is uniform throughout and does not rely on any type of paint coating to achieve color stability.

Physical Characteristics:

The cast in place detectable warning systems must have a slip resistance coefficient of 1.18-Dry/1.05-Wet or better.

The detectable warning system must resist chemical staining, freezing and heating.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0900:**

This work consists of preparing seed beds and sowing grass seed utilizing hydro-seeding equipment and methods in order to establish a turf grass cover to areas designated in the plans or as directed in accordance with Section 739 of the Louisiana Standard Specifications for Roads and Bridges, Latest Edition. This item will be paid at the contract unit price per square yard of hydro-seeding installed. Including all necessary labor, equipment, materials and incidentals required for completion of work.

**THE BELOW SPECIFICATIONS APPLY TO
ITEM 0910:**

This work consists of furnishing and installing geotextile fabric (Class D) on/under road bed surface, in conformity with the requirements of Section 1019 of the LADOTD Standard Specifications for Roads and Bridges, Latest Edition.

Bid prices for this item are to include all costs for labor, materials and equipment necessary to install geotextile fabric approved by Department of Streets representative. Installation shall be in accordance with the manufacturer's specifications, instruction and procedure.

**THE BELOW SPECIFICATIONS WILL APPLY TO
ITEMS 0920 AND 0930:**

Geogrid

This work consists of furnishing and installing geogrid in locations designated and/or directed by the engineer.

Installation must be in strict accordance with manufacturer's instructions and requirements.

Geogrid will be paid for per square yard, which includes furnishing all equipment, labor, materials and incidentals necessary to complete the work.

The geogrid shall conform in all respects to the physical property values listed in the manufacturing specifications. The listed property values are certifiable minimum average roll values unless otherwise noted and are equal to the mean value less one standard deviation which reflects the desired 95% confidence level. These values are subject to verification by an independent laboratory.

Alternate Material

Alternate geogrid materials will be considered. Such materials should be pre-approved in writing by the engineer prior to bid date. Alternate material packages should be submitted to the engineer a minimum of 15 days prior to bid date. Submittal packages should include the following as a minimum:

1. Full-scale laboratory testing and in-ground testing of pavement structures reinforced with the specific geogrid which illustrates significant structural contribution of the geogrid to the pavement structure.
2. Certified test results stating that the alternative geogrid has a secant aperture stability modulus at 20 cm-kg. when tested in accordance with the "Grid Aperture Stability by Inplate Rotation" Test of 3.2 or greater for Type 1 and 6.50 or greater for Type 2.
3. A design guideline illustrating flexible pavement design methods implementing the alternate geogrid.
4. A list of 10 comparable projects, in terms of size and application, in the United States, where the results of the specific alternate geogrid's use can be verified after a minimum of 3 years of service life.

5. A sample of the geogrid and certified material property data sheets.
6. Recommended installation instructions.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 0940 AND 0950:**

Fibrous Material

The mat in different widths shall be applied over longitudinal PCC joints, traverse joints and cracks and random cracks according to specifications prior to resurfacing concrete or asphalt pavements.

The mat material shall be a heavy-duty crack reduction/stress relief interlayer material consisting of a flexible high density asphaltic membrane laminated between 6oz/sy woven polyester geotextile. The mat shall be pave-prep type (S) standard and type (SA) self adhesive or equal. The alternatives shall meet or exceed the physical properties stipulated by pave-prep. Any alternatives have to be approved by this department prior to its usage on the job.

Application and installation of the material shall strictly follow manufacturer's specifications. Contractor shall submit manufacturer's technical data on the fibrous material properties for approval a minimum of 15 days prior to its use in the field. Submittal shall also include documentation supporting the successful use of the product for a minimum of 5 years. The bid unit price for the fibrous material shall include the cost of the material, equipment, labor and all other incidentals. There will be no other compensation.

**THE BELOW SPECIFICATIONS APPLY TO ITEMS
0970 THRU 1000:**

Bid prices for this item shall include all costs for labor, material and equipment necessary to install conventional Portland cement concrete curb and gutter (barrier or roll-over) with a maximum cross section area of (200, 250, 300 or 400) square inches as specified in the item description. Payment shall be per linear foot of curb installed.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1030:**

For this item the contractor shall saw cut a groove in a roadway (asphalt/concrete), install loop wire, seal the saw cut with sealant and make connections of loop wire to lead in cable. Details of saw cut and loop wire installations are available at Jefferson Parish Traffic Division (736-6530). The Jefferson Parish Traffic Engineering Division shall determine the size and placement of the loop(s) as per transmittal. Inductance loop is typically 6' x 6'.

Ruscoe No. 983 traffic detector loop sealant, Preco gold label flex 1P loop sealant, 3M brand loop sealant, safety coatings loop guard for loop detector sealant or approved equal shall be used to seal loop wires in roadway.

Saw cutting and sealant required to complete this task shall be included in the per foot cost of this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1040:**

Conduit in earth installation or replacement. The Jefferson Parish Traffic Engineering Division (736-6530), shall determine the size and placement of conduit as needed.

All schedule No. 40 polyvinyl chloride conduit (P.V.C.) and fittings as noted in Section 1 for underground installation.

All joints shall be solvent welded and watertight.

Conduit to be installed a minimum of three feet (3') below grade, unless otherwise specified by the Traffic Engineering Division. When boring operations are employed, the contractor shall bore from one side of the roadway to the other. All excavations on side of roadway are to be restored to their original condition.

Any excavation and backfill required to perform this task shall be included in the per foot cost of this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1050:**

Make: _____
Model: _____
H.P. _____

Bid prices shall include all costs for hourly rental of conventional heavy duty road grader, with scarifier and operator. Rental of the equipment will be for specific projects under control of the Department of Streets and will be assigned project job numbers. The use of road graders by the contractor in the performance of items of work as listed elsewhere under this contract will not be billed separately under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1060:**

Bid prices shall include all costs for hourly rental of a self-contained, mobile, heavy-duty pavement breaker with operator. Rental of this will be for work under control of the Department of Streets. The use of pavement breakers by the contractor in the performance of items of work as listed elsewhere under this contract will not be billed separately as under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1070:**

Bids should include all costs for hourly rental of a grade-all class 5100, or equal, with operator. Rental of this equipment will be for work under control of the Department of Streets. The use of a grade-all by the contractor in the performance of items of work as listed elsewhere under this contract will not be billed separately as under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1080 AND 1090:**

Bid prices should include all costs for hourly rental of a dump truck, tandem/trailer, 12/24 cubic yard minimum capacity with driver. Rental of this vehicle will be for work under control of the Department of Streets. The use of tandem/trailer dump trucks by the contractor in the performance of items of work as listed elsewhere under this contract will not be billed separately as under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1100:**

Bid price should include all costs for hourly rental of a street sweeper 10' sweep pattern, 8' main broom, (2) two 2' side brooms and 3.5 cubic yard minimum front loading hopper with operator. Rental of this equipment will be for work under control of Department of Streets. Use of street sweeper in the performance of items of work listed elsewhere under this contract will not be billed separately under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEMS 1110:**

Bid prices should include all costs for hourly rental of a dozer model D-3, or equivalent, with operator. Rental of this equipment will be for work under control of Department of Streets. Use of dozer in the performance of items of work listed elsewhere under this contract will not be billed separately under this item.

**THE BELOW SPECIFICATIONS APPLY TO
ITEM 1140:**

This item represents the additional fee (expressed in %) owed to the contractor for night work.

Night work is defined as work performed between the hours of 7:00PM and 7:00AM.

While performing night work, only those items used will be payable under the night work Line Item 1140.

Additional fee for night work is to be expressed in percentage and dollar amount as follows:

- A. Sum of "Totals" for Items 0010 through 1130.
\$ _____
- B. Indicate percentage (%) that will be charged for Items 0010 through 1130 that are used while performing night work.
_____ %
- C. For bidding purposes, the Parish anticipates that 3% of all work performed under this contract will be night work. That anticipated percentage (3%) may be more or may be less. Multiply that percentage (3%) by your percentage (%) (From B, above) that will be charged for night work to be used in the calculation below.
- D. Multiply the dollar amount of (A) by the percentage (%) derived from (C) to get a dollar value. This total is to be entered as "Unit Price Quoted" for Item 1140.

For Bidding Purposes:

The "Unit Price Quoted" above (D) will only be used in determining the low bid.

For Invoicing Purposes:

The percentage (%) indicated above in (B) will be used for invoicing of night work.

The contractor will be required to submit separate invoices for night work.

CURBS:

The Portland cement concrete mixture for curb construction shall be a minimum of 4000 PSI/72 hour, high early strength and also will provide proper workability, curb strength, and minimum contraction cracking. The concrete mix shall conform to Louisiana Department of Transportation and Development Standard Specifications for Roads and Bridges, Latest Edition. PCC curbing may be placed by extruding machine or by forming and hand placement at contractor's option and will be bonded to holding surface in a manner approved by the Department of Streets, which may include doweling and/or approved bonding agent. Curbing may also be poured monolithically with the panel.

The accepted quantities of curbs will be paid for at the contract unit price per linear foot on existing panels (incidental to square yard cost of new pavement), including all labor, equipment and materials incidental to the work.

No additional payment will be made for the removal of any type of existing curb and/or curb dowels.

RECYCLED PORTLAND CEMENT CONCRETE:

Recycled Portland cement concrete shall be used from approved stockpiles. Stockpiles of crushed concrete shall be uniform and free from soils, reinforcing steel, debris, excessive amount of asphaltic materials and other foreign matter. Material sampling shall be in accordance with the requirements for stone by the Louisiana Department of Transportation and

Development's, Latest Edition and Revisions and all applicable sections of the materials sampling manual. Crushed concrete shall conform to the abrasion and soundness requirements of the Standard Specifications for Roads and Bridges, Latest Edition and conform to the following gradation:

Class I

U. S. Sieve	Percent Passing
1-1/2"	100
1"	90-100
3/4"	70-100
No. 4	35-65
No. 40	12-32
No. 200	5-16

Aggregate passing the No. 40 sieve shall have a maximum plasticity index of 6.

Class II

Crushed concrete in Class II gradation shall have 100% passing through 4 inch mesh and a maximum of 20% passing through 2 inch mesh.

Crushed concrete in Class II shall be bid under item for crushed concrete.

SAND

Sand shall conform to the following requirements:

Liquid Limit (Maximum)	25%
Plasticity Index (Maximum)	6%

CRACK AND JOINT SEALING (SEE ITEM 0890):

This item is to provide general sealing of cracks and/or joints in existing pavement. This work would usually be done in areas contiguous to a paving project being done under this contract. Bid prices should include all costs for labor, materials and equipment required to apply an approved liquid poured sealant of the asphalt type as specified under Section 1005.02 of LADOTD Specifications for Roads and Bridges, Latest Edition and Revisions. Cracks and/or joint shall be cleaned and chipped if necessary in accordance with generally accepted procedures prior to pouring the sealant.

REINFORCING STEEL:

This work consists of furnishing fabricating and placing reinforcing steel for reinforced Portland cement concrete structures.

Reinforcing steel shall be Grade 60 deformed bars conforming to ASTM 615, in accordance with Sections 806 and 1009 of the LADOTD Standard Specifications for Roads and Bridges, Latest Edition.

Reinforcing steel will be paid for by the pound, which includes furnishing all equipment, labor and materials necessary to complete the work, unless used in conjunction with another item that includes reinforcing steel as incidental to its unit price, (such as items 0280, 0290, and 0300).

TESTING:

The parish at its own will and expense can appoint an independent testing laboratory for material and construction testing. No advance notice of testing will be provided to the contractor. Also testing by parish will not relieve contractor from his own testing procedures. In the event test results by contractor or parish do not meet the required specifications, contractor shall replace or reconstruct and correct all the deficiencies to satisfy the specifications. There shall be no adjustment in bid price for additional pavement thickness detected as a result of any testing.

GENERAL:

It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission; and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the inspector general in any investigation, audit, inspection, performance review, or hearing pursuant to this chapter. Every parish contract and every bid, proposal, application or solicitation for a parish contract, and every application for certification of eligibility for a parish contract or program shall contain a statement that the corporation, partnership, or person understands and will abide by all provisions of this chapter.

LOUISIANA UNIFORM PUBLIC WORK BID FORM

50-00133108

Page: 6

REVISED PER ADDENDUM 1

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
 (Owner to provide name and address of owner)

BID FOR: CONCRETE (STREET) MAINTENANCE F
 JEFFERSON PARISH DEPARTMENT OF
 WORKS, STREETS AND ALL JEFFERSON
 AGENCIES AND MUNICIPALITIES (EX
 (Owner to provide name of project and
 other identifying information)

The undersigned bidder hereby declares and represents that she/he; a) has carefully examined and understands the Bidding Documents, b) has not received, relied on, or based his bid on any verbal instructions contrary to the Bidding Documents or any addenda, c) has personally inspected and is familiar with the project site, and hereby proposes to provide all labor, materials, tools, appliances and facilities as required to perform, in a workmanlike manner, all work and services for the construction and completion of the referenced project, all in strict accordance with the Bidding Documents prepared by: _____

_____ and dated: _____
 (Owner to provide name of entity preparing bidding documents.)

Bidders must acknowledge all addenda. The Bidder acknowledges receipt of the following ADDENDA: (Enter the number the Designer has assigned to each of the addenda that the Bidder is acknowledging) _____

TOTAL BASE BID: For all work required by the Bidding Documents (including any and all unit prices designated "Base Bid" * but not alternates) the sum of:

_____ Dollars (\$) _____

ALTERNATES: For any and all work required by the Bidding Documents for Alternates including any and all unit prices designated as alternates in the unit price description.

Alternate No. 1 (Owner to provide description of alternate and state whether add or deduct) for the lump sum of:

N/A _____ Dollars (\$) _____

Alternate No. 2 (Owner to provide description of alternate and state whether add or deduct) for the lump sum of:

N/A _____ Dollars (\$) _____

Alternate No. 3 (Owner to provide description of alternate and state whether add or deduct) for the lump sum of:

N/A _____ Dollars (\$) _____

NAME OF BIDDER: _____

ADDRESS OF BIDDER: _____

LOUISIANA CONTRACTOR'S LICENSE NUMBER: _____

NAME OF AUTHORIZED SIGNATORY OF BIDDER: _____

TITLE OF AUTHORIZED SIGNATORY OF BIDDER: _____

SIGNATURE OF AUTHORIZED SIGNATORY OF BIDDER **: _____

DATE: _____

THE FOLLOWING ITEMS ARE TO BE INCLUDED WITH THE SUBMISSION OF THIS LOUISIANA UNIFORM PUBLIC WORK BID FORM:

* The Unit Price Form shall be used if the contract includes unit prices. Otherwise it is not required and need not be included with the form. The number of unit prices that may be included is not limited and additional sheets may be included if needed.

** A CORPORATE RESOLUTION OR WRITTEN EVIDENCE of the authority of the person signing the bid for the public work as prescribed by LA-R.S. 38:2218 (B)(5).

BID SECURITY in the form of a bid bond, certified check or cashier's check as prescribed by LA-R.S. 38:2218.(A) is attached to and made a part of this bid.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

REVISED PER ADDENDUM 1

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0010 PCC 4 INCH THICK (REMOVAL/DISPOSAL REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE FOR SIDEWALK	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0010	1,760.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0020 PCC 5 INCH THICK (REMOVAL/DISPOSAL/ REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, FOR INCIDENTAL CONCRETE, IN PLACE	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0020	100.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0030 PCC 6 INCH THICK (REMOVAL/DISPOSAL/ REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS IN PLACE FOR DRIVE- WAY APRON (W/O STEEL MESH REINFORCEMENT)	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0030	4,200.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0040 PCC 6 INCH THICK (REMOVAL/DISPOSAL/ REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS IN PLACE FOR HANDICAPPED RAMP WITH 6X6 - W2.9 STEEL	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0040	1,000.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0050 PCC 7 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE (LESS THAN 50 SQ YD PER JOB)	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0050	200.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0060 PCC 7 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE (50 SQ YD OR GREATER PER JOB)	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0060	65,000.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0070 PCC 8 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0070	100.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0080 PCC 8 INCH THICK (REMOVAL/DISPOSAL/ REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS IN PLACE FOR HANDICAPPED RAMPS WITH 6X6 - W2.9 STEEL	
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0080	250.00	SQYD	

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0090 PCC 9 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW) HIGH EARLY STRENGTH 4000 PSI - 72 HOURS IN PLACE (LESS THAN 50 SQ YD PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0090	275.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0100 PCC 9 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE (50 SQ YD AND GREATER PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0100	8,800.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0110 PCC 10 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE (LESS THAN 50 SQ YDS PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0110	100.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0120 PCC 10 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 72 HOURS, IN PLACE (50 SQ YD AND GREATER PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0120	1,500.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0130 PCC 6 INCH THICK (REMOVAL/DISPOSAL/ REPLACEMENT OR NEW), HIGH EARLY STRENGT 4000 PSI - 24 HOURS, IN PLACE FOR DRIVEWAY APRON (WITHOUT STEEL MESH)
REF NO.	QUANTITY	UNIT OF MEASURE
0130	100.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0140 PCC 7 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (LESS THAN 50 SQ YD PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0140	200.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0150 PCC 7 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (50 SQ YD AND GREATER PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0150	200.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0160 PCC 9 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (LESS THAN 50 SQ YD PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0160	50.00	SQYD

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0170 PCC 9 INCH INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (50 SQ YD AND GREATER PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0170	100.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0180 PCC 10 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (LESS THAN 50 SQ YD PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0180	50.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0190 PCC 10 INCH THICK INCLUDING CURB (REMOVAL/DISPOSAL/REPLACEMENT OR NEW), HIGH EARLY STRENGTH 4000 PSI - 24 HOURS, IN PLACE (50 SQ YD AND GREATER PER JOB)
REF NO.	QUANTITY	UNIT OF MEASURE
0190	100.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0192 PCC REMOVAL (ONLY), 6.5 INCH OR LESS
REF NO.	QUANTITY	UNIT OF MEASURE
0192	150.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0194 PCC REMOVAL (ONLY), GREATER THAN 6.5 INCH TO 10 INCH
REF NO.	QUANTITY	UNIT OF MEASURE
0194	500.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0200 WASHED GRAVEL (PAVEMENT SURFACE)
REF NO.	QUANTITY	UNIT OF MEASURE
0200	20.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0210 SLATE (PAVEMENT SURFACE)
REF NO.	QUANTITY	UNIT OF MEASURE
0210	20.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#	0220 STONE PAVERS (PAVEMENT SURFACE)
REF NO.	QUANTITY	UNIT OF MEASURE
0220	20.00	SQYD

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST, SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0230 BRICK PAVERS (PAVEMENT SURFACE)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0230	20.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0240 STAMPED CONCRETE (PAVEMENT SURFACE)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0240	20.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0242 PERVIOUS CONCRETE PAVEMENT (6 INCH OR LESS)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0242	50.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0244 PERVIOUS CONCRETE PAVEMENT (GREATER THAN 6 INCH UP TO 9 INCH)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0244	125.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0250 PCC CURB (ONLY), EXTRUDED 8 IN HGT HIGH EARLY STRENGTH 4000 PSI - 72 HRS BARRIER TYPE (INCLUDES NO. 4 (U) SHAPED CURB DOWEL SPACED 2 FT-0 IN OC ANCHORED	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0250	100.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0260 PCC CURB (ONLY), EXTRUDED 6 IN HGT HIGH EARLY STRENGTH 4000 PSI - 72 HRS BARRIER TYPE (INCLUDES NO. 4 (U) SHAPED CURB DOWEL SPACED 2 FT-0 IN OC ANCHORED	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0260	200.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0270 PCC CURB (ONLY), EXTRUDED 5 IN ROLLOVER TYPE HIGH EARLY STRENGTH 4000 PSI - 72 HRS (INCLUDES NO. 4 (U) SHAPED DOWELS SPACED 2 FT-0 INCH O.C. ANCHORED	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0270	400.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0280 PCC (7 INCH THICK) BOXING FOR MANHOLES/CATCH BASINS (REMOVAL/REPLACE- MENT OR NEW)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0280	800.00	SQYD	

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES (**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0290 PCC (9 INCH THICK) BOXING FOR MANHOLES/CATCH BASINS (REMOVAL REPLACE- MENT OR NEW)
REF NO.	QUANTITY	UNIT OF MEASURE
0290	75.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0300 PCC (10 INCH THICK) BOXING FOR MANHOLES/CATCH BASINS (REMOVAL/REPLACE- MENT OR NEW)
REF NO.	QUANTITY	UNIT OF MEASURE
0300	25.00	SQYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0310 EARTHWORK EXCAVATION BY TRUCK MEASURE
REF NO.	QUANTITY	UNIT OF MEASURE
0310	100.00	CUYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0320 EARTHWORK EXCAVATION BY THEORETICAL VOLUME
REF NO.	QUANTITY	UNIT OF MEASURE
0320	200.00	CUYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0330 RIVER (BATTURE) SAND
REF NO.	QUANTITY	UNIT OF MEASURE
0330	100.00	CUYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0340 PUMP (SUGAR) SAND
REF NO.	QUANTITY	UNIT OF MEASURE
0340	3,700.00	CUYD

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0350 LIMESTONE
REF NO.	QUANTITY	UNIT OF MEASURE
0350	300.00	TN

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0360 CRUSHED CONCRETE CLASS I OR II
REF NO.	QUANTITY	UNIT OF MEASURE
0360	50.00	TN

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

REVISED PER ADDENDUM 1

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0370 REINFORCED CONCRETE 15 INCH DIAMETER, RCP, C-76, CLASS III, RUBBER GASKET, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0370	8.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0380 REINFORCED CONCRETE 18 INCH DIAMETER, RCP, C-76, CLASS III, RUBBER GASKET, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0380	8.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0390 REINFORCED CONCRETE 24 INCH DIAMETER, RCP, C-76, CLASS III, RUBBER GASKET, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0390	8.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0400 REINFORCED CONCRETE 30 INCH DIAMETER, RCP, C-76, CLASS III, RUBBER GASKET IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0400	8.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0410 6 INCH DIAMETER, P.V.C. PIPE, SDR 35, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0410	70.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0420 8 INCH DIAMETER, P.V.C. PIPE, SDR 35, PERFORATED, 1/2 INCH DIAMETER HOLE, 12 INCH CENTER TO CENTER, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0420	14.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0430 8 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0430	14.00	LF

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0440 10 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE
REF NO.	QUANTITY	UNIT OF MEASURE
0440	28.00	LF

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

REVISED PER ADDENDUM 1

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0450 12 INCH DIAMETER, P.V.C. PIPE, SDR 35, IN PLACE <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0450	56.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0460 15 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0460	14.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0470 18 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0470	14.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0480 24 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0480	14.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0490 30 INCH DIAMETER, P.V.C. PIPE SDR 35, IN PLACE <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0490	14.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0500 12 INCH DIAMETER, A-2000 PIPE IN PLACE, (AS APPROVED BY LADOTD-QPL66) <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0500	264.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0510 15 INCH DIAMETER, A-2000 PIPE IN PLACE (AS APPROVED BY LADOTD-QPL66) <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0510	110.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid 0520 18 INCH DIAMETER , A-2000 PIPE IN PLACE (AS APPROVED BY LADOTD-QPL66) <input type="checkbox"/> Alt.# _____			
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0520	22.00	LF		

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0530 21 INCH DIAMETER, A-2000 PIPE IN PLACE (AS APPROVED BY LADOTD-QPL66)		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0530	22.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0540 24 INCH DIAMETER, A-2000 PIPE IN PLACE (AS APPROVED BY LADOTD-QPL66)		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0540	22.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0550 24 INCH DIAMETER, CMP, RIBBED POLYMER COATED, 12 GA, INSTALLED		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0550	20.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0560 27 DIAMETER, CMP, RIBBED POLYMER COATED, 12 GA, INSTALLED		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0560	20.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0570 30 INCH DIAMETER, CMP, RIBBED POLYMER COATED, 12 GA, INSTALLED		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0570	20.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0580 CONVERT TYPE I CATCH BASIN (VERTICAL FACE) TO TYPE III (STANDARD ROLLOVER GRATE WITH FRAME)		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0580	5.00	EA		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0590 CONVERT TYPE I CATCH BASIN TO 24 INCH X 36 INCH DROP INLET WITH FRAME AND GRATE		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0590	1.00	EA		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0600 CONVERT EXISTING DRAIN INLET/CATCH BASIN TO MANHOLE (INCLUDES CASTINGS, COVER AND ALL RELATED WORK)		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0600	1.00	EA		

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST, SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0610 CONVERT TYPE I CATCH BASIN TO 24 INCH X 36 INCH OR ROLLOVER INCLUDING MANHOLE COVER AND GRATE
REF NO.	QUANTITY	UNIT OF MEASURE
0610	1.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0620 YARD DRAIN, 12 INCH X 12 INCH OPEN GRATE WITH FRAME, 4 INCH BRICK WALL, 6 INCH CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0620	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0630 DROP INLET, 18 INCH X 18 INCH OPEN GRATE WITH FRAME, 8 INCH BRICK WALL, 6 INCH REINFORCED CONCETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0630	10.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0640 DROP INLET, 24 INCH X 24 INCH OPEN GRATE WITH FRAME, 8 INCH BRICK WALL, 6 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0640	10.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0650 DROP INLET, 24 INCH X 36 INCH OPEN GRATE WITH FRAME, 8 INCH BRICK WALL, 6 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0650	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0660 CATCH BASIN, STANDARD ROLLOVER TYPE II, 8 INCH BRICK WALL, 8 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0660	10.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0670 CATCH BASIN, STANDARD, TYPE I VERTICAL FACE, 8 INCH BRICK WALL, 8 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0670	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0680 DRAINAGE MANHOLE, STANDARD, 8 INCH BRICK WALL, AVERAGE 48 INCH BOTTOM DIAMETER, 8 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0680	5.00	EA

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0690 CONFLICT BOX FOR CONFLICTING UNDERGROUND UTILITIES (INCLUDES CASTINGS, COVER AND ALL RELATED WORK)
REF NO.	QUANTITY	UNIT OF MEASURE
0690	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0700 CATCH BASIN, NO. 5-8 INCH BRICK WALL,, TYPE I, VERTICAL FACE WITH FLAT GRATE IN THE GUTTER
REF NO.	QUANTITY	UNIT OF MEASURE
0700	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0710 CATCH BASIN, STANDARD, TYPE III, 8 INCH BRICK WALL, 8 INCH CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0710	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0720 CATCH BASIN, STANDARD, TYPE IV, 8 INCH BRICK WALL, 8 INCH CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0720	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0730 JUNCTION BOX, STANDARD 8 INCH BRICK WALL, 24 IN X 36 IN OPEN GRATE COVER WITH FRAME, 8 INCH REINFORCED CONCRETE SLAB FOUNDATION
REF NO.	QUANTITY	UNIT OF MEASURE
0730	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0740 STRUCTURAL GRADE ADJUSTMENTS (ELEV.) TO EXISTING CATCH BASIN/MANHOLE (NON-REINFORCED)
REF NO.	QUANTITY	UNIT OF MEASURE
0740	400.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0750 STRUCTURAL GRADE ADJUSTMENTS EXISTING REINFORCED CONCRETE CATCH BASIN - SINGLE OR MANHOLE
REF NO.	QUANTITY	UNIT OF MEASURE
0750	5.00	EA

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0760 STRUCTURAL GRADE ADJUSTMENTS EXISTING REINFORCED CONCRETE CATCH BASINS - DOUBLED NO. 1 CATCH BASINS
REF NO.	QUANTITY	UNIT OF MEASURE
0760	5.00	EA

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

REVISED PER ADDENDUM 1
CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES (

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0770 RING ADJUSTMENTS, PER INCH TO EXISTING MANHOLE	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0770	5.00	EA	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0780 MISCELLANEOUS TIE-INS, BLIND TIE, INCLUDES TEE IF NEEDED (YARD DRAINS, FILTER BEDS, ETC.)	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0780	10.00	EA	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0790 JUNCTION BOX (SPECIAL) 6 FT TO 8 FT DEPTH, BRICK WALL, 12 INCH THICK REINFORCED CONCRETE BASE SLAB 12 INCH THICK AREA 64 SQ. FT +/-	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0780	1.00	EA	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0800 JUNCTION BOX (SPECIAL) 8 FT TO 10 FT. DEPTH, BRICK WALL, 12 INCH THICK REINFORCED CONCRETE BASE SLAB 12 INCH THICK AREA 100 SQ. FT. +/-	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0800	1.00	EA	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0810 ASPHALT OR PCC SAW CUT, PER INCH DEPTH	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0810	20,000.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0820 LIQUID POURED ASPHALT TYPE SEALANT APPLIED PER GALLON	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0820	20.00	GL	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0830 DETECTABLE WARNING PAD(24IN X 48IN) W/RAISED TRUNCATED DOMES PER ADA GUIDES VISUALLY CONTRASTING W/ADJOINING SURFACE TERRA COTTA IN PLACE FOR CURB RAMPS/LOAD	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0830	100.00	EA	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0840 FURNISH AND INSTALL WIRE MESH REINFORCEMENT - 6X6-W2.9XW2.9 FOR PAVEMENT & WALKWAYS AS NEEDED (NOT USED IF WIRE MESH IS INCIDENTAL TO OTHER	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0840	2,500.00	SQYD	

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0850 SHEETING IN PLACE SHEETING MATERIAL SHOULD BE OAK DUNNAGE (2 INCH X 12 INCH, ACTUAL DIMENSIONS)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0850	250.00	FT	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0860 ST. AUGUSTINE GRASS SOD/CENTPEDE GRASS SOD	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0860	4,500.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0870 BERMUDA GRASS SEED	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0870	30.00	LB	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0880 RYE GRASS SEED	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0880	5.00	LB	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0890 8-8-8 GRANULAR FERTILIZER	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0890	30.00	LB	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0900 HYDRO-SEEDING	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0900	100.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0910 GEOTEXTILE FABRIC (CLASS D)	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0910	500.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	0920 GEOGRID BASE REINFORCEMENT AND GEO SUB-GRADE IMPROVEMENT TYPE I, BOX 1100	
	<input type="checkbox"/> Alt.#		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
0920	5.00	SQYD	

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST., SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0930 GEOGRID BASE REINFORCEMENT AND GEO SUB-GRADE IMPROVEMENT TYPE II, BOX 1200		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0930	5.00	SQYD		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0940 FIBROUS MATERIAL: PAVE PREP TYPE S		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0940	5.00	SQFT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0950 FIBROUS MATERIAL: PAVE PREP TYPE SA		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0950	5.00	SQFT		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0960 REINFORCING STEEL BARS. IN PLACE		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0960	7,000.00	LB		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0970 CONCRETE CURB AND GUTTER ROLLOVER OR BARRIER, 200 SQ. IN. CROSS SECTION MAX, 4000 PSI		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0970	500.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0980 CONCRETE CURB AND GUTTER ROLLOVER OR BARRIER, 250 SQ. IN. CROSS SECTION MAX, 4000 PSI		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0980	100.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	0990 CONCRETE CURB AND GUTTER ROLLOVER OR BARRIER, 300 SQ. IN. CROSS SECTION MAX, 4000 PSI		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
0990	100.00	LF		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid <input type="checkbox"/> Alt.#__	1000 CONCRETE CURB AND GUTTER ROLLOVER OR BARRIER, 400 SQ. IN. CROSS SECTION MAX, 4000 PSI		
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
1000	50.00	LF		

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
**CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES**
(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1010 COLD MILLING EXISTING ASPHALT (PER INCH DEPTH)	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1010	5.00	SQYD	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1020 BITUMINOUS HOT MIX ASPHALT PATCHING AND LEVELING	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1020	1.00	TN	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1030 VEHICLE DETECTOR INDUCTIVE LOOP INSTALLATION OR REPLACEMENT	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1030	5.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1040 1 INCH, 2 INCH, OR 3 INCH P.V.C. CONDUIT IN EARTH	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1040	5.00	LF	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1050 ROAD GRADER AND OPERATOR (VENDOR TO INDICATE TYPE OF GRADER TO BE FURNISHED)	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1050	8.00	HR	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1060 PAVEMENT BREAKER, SELF-CONTAINED MOBILE WITH OPERATOR	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1060	8.00	HR	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1070 GRADE-ALL WITH OPERATOR	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1070	8.00	HR	

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1080 DUMP TRUCK, TANDEM, 12 CU. YD. MINIMUM CAPACITY WITH DRIVE	<input type="checkbox"/> Alt.#
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1080	8.00	HR	

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

Bid# 50-00133108

TO: JEFFERSON PARISH
PURCHASING DEPT
200 DERBIGNY ST. SUITE 4400
GRETN, LA 70053
(Owner to provide name and
address of owner)

REVISED PER ADDENDUM 1
CONCRETE (STREET) MAINTENANCE FOR THE
JEFFERSON PARISH DEPARTMENT OF PUBLIC
WORKS, STREETS AND ALL JEFFERSON PARISH
AGENCIES AND MUNICIPALITIES /

(Owner to provide name of project
and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices.
Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1090 DUMP TRUCK, TRAILER, 24 CU. YD. MINIMUM CAPACITY WITH DRIVER	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1090	8.00	HR	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1100 STREET SWEEPER 10 FT. SWEEP PATTERN 8 FT. MAIN BROOM, TWO (2) FT. SIDE BROOMS 3.5 CUYD (MIN.) FRONT LOADING HOPPER WITH OPERATOR	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1100	8.00	HR	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1110 DOZER/D3 OR EQUAL WITH OPERATOR	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1110	8.00	HR	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1120 NORTH AMERICAN GREEN S75 STRAW EROSION CONTROL BLANKET OR EQUIVALENT	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1120	5.00	SQYD	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1130 NORTH AMERICAN GREEN S150 STRAW EROSION CONTROL BLANKET OR EQUIVALENT	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1130	5.00	SQYD	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid	1140 NIGHT WORK	<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
1140	1.00	JOB	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input type="checkbox"/> Base Bid		<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
			UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input type="checkbox"/> Base Bid		<input type="checkbox"/> Alt.#__
REF NO.	QUANTITY	UNIT OF MEASURE	UNIT PRICE
			UNIT PRICE EXTENSION (Quantity times Unit Price)

Wording for "DESCRIPTION" is to be provided by the Owner.
All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner.